




Contents list available at IJRED website

Int. Journal of Renewable Energy Development (IJRED)

Journal homepage: <http://ejournal.undip.ac.id/index.php/ijred>



# Comparison Between Conventional Design and Cathode Gas Recirculation Design of a Direct-Syngas Solid Oxide Fuel Cell–Gas Turbine Hybrid Systems Part I: Design Performance

Vahid Azami <sup>a,\*</sup> and Mortaza Yari <sup>b</sup>

<sup>a</sup> Department of Mechanical Engineering, Mohaghegh Ardabili University, Ardabil, Iran

<sup>b</sup> Department of Mechanical Engineering, Tabriz University, Tabriz, Iran

**ABSTRACT.** In this paper, a conventional SOFC–GT hybrid system and an SOFC–GT hybrid system with cathode gas recirculation system fuelled with syngas as the main source of energy were analyzed and their performances were compared. In the conventional SOFC–GT hybrid system the incoming air to the cathode is heated at the air recuperator and air preheater to meet the required cathode inlet temperature while in the SOFC–GT hybrid system with cathode gas recirculation, in addition to the air recuperator and air preheater, also the recirculation of the cathode exhaust gas is used to meet the required cathode inlet temperature. The system performances have been analyzed by means of models developed with the computer program Cycle–Tempo. A complete model of the SOFC–GT hybrid system with these two configurations evaluated in terms of energy and exergy efficiencies and their performance characteristics were compared. Simulation results show that the electrical energy and exergy efficiencies achieved in the cathode gas recirculation plant (64.76% and 66.28%, respectively) are significantly higher than those obtained in the conventional plant (54.53% and 55.8%).

**Keywords:** Solid oxide fuel cell, Gas turbine, Cathode gas recirculation, Exergy.

**Article History:** Received Feb 23<sup>rd</sup> 2017; Received in revised form May 26<sup>th</sup> 2017; Accepted June 1<sup>st</sup> 2017; Available online

**How to Cite This Article:** Azami, V, and Yari, M. (2017) Comparison between conventional design and cathode gas recirculation design of a direct-syngas solid oxide fuel cell–gas turbine hybrid systems part I: Design performance. International Journal of Renewable Energy Development, 6(2), 127-136.  
<https://doi.org/10.14710/ijred.6.2.127-136>

## 1. Introduction

One of the promising technologies for power generation is fuel cell. Within the fuel cell types, solid oxide fuel cell are being paid much attention because of their advantages like high efficiency and flexibility for different fuels, furthermore when operated at high pressures, they can be combined with gas turbines for obtaining very high efficiency for electricity generation. The hybrid system of solid oxide fuel cell combined with gas turbine (SOFC–GT) cycle has been identified to be a superior power generation technology compared to many other options. Siemens–Westinghouse Power Corporation developed the first advanced power system, which integrates a SOFC stack with the gas turbine engines. The pressurize system with operating pressure 3 atm generates 220

kW of electrical power at a net electrical efficiency of 55% (Hirschenhofer *et al.* 2008).

In spite of the introduction of many innovative cycles for the SOFC–GT hybrid system, its universal configuration is not yet fully established. Studies to develop new system configurations for better performance are still in progress. In this regard, a number studies were analysed ambient pressure design of hybrid SOFC–GT system and performances were compared with a pressurized system, like the studies of Park *et al.* (2006; 2009). Kuchonthara *et al.* (2003) evaluated a combination of SOFC and various gas turbine cycles such as STIG cycle, gas turbine/steam turbine combined cycle and humid air turbine (HAT) cycle. In the STIG cycle, the generated steam is injected into a GT combustion chamber in

\* Corresponding author: [vazami@uma.ac.ir](mailto:vazami@uma.ac.ir)





afterburner. Various types of design are available for solid oxide fuel cell. Direct internal reforming fuel cell is selected for the present study.

**Table 1**

Dry composition of the syngas used in the models (Ankur 2010)

Component	Unit	Value
CH <sub>4</sub>	mol%	3
H <sub>2</sub>	mol%	18
N <sub>2</sub>	mol%	50
CO <sub>2</sub>	mol%	10
CO	mol%	19
LHV	kJ/kg	4939

In the combustor a chemical reaction takes place between the fuel and oxidant. In order to determine the heat produced, it is therefore essential to calculate this composition. Under ideal conditions (residence time, mixture), the composition of the flue gas will be the same as the equilibrium composition corresponding to the composition of the reactants and the reaction conditions ( $p_{\text{react}}, T_{\text{react}}$ ).

The gas turbine operates with a typical recuperated Brayton cycle. It consists of a compressor, a recuperator, a burner, a turbine as well as a generator. In this paper, assume that it is possible to design turbines with the specific characteristics mentioned in this study (see Table 2). The power level given for the gas turbine generator determined the fuel mass flow gets into the system and hence fuel mass flow gets into the combustor. On the other hand, the cooling air required to keep the fuel cell at the required operating temperature determine the air mass flow rate gets into the system and hence air mass flow gets into the combustor. The description of the SOFC/GT hybrid system models is given in Refs. (Aravind 2009; Toonssen 2010; Cycle-tempo manuals 2017).

The energy equation of the heat exchanger can be used in two ways in the model calculation. The first option uses the energy equation to calculate an unknown mass flow ratio. In this option, first the enthalpies are determined. The enthalpies can be calculated when two state variables in the relevant pipe are known. In the second option the energy equation is used to calculate an unknown enthalpy. When a second state variable (e.g. the pressure) in the relevant pipe is known, the unknown temperature can be calculated. When the energy equation is used to calculate an unknown temperature, the mass flows ratio must be known from the energy equation. For the first iteration run an initial value is chosen for the mass flow ratio. For the following iteration runs the mass flows are used which are calculated in the previous iteration run. The unknown temperature is then known as a function of the enthalpy and another state property.

They are two ways to start the iteration in the program. One way is to specify the fuel mass flow ratio and the other way is to set the power output load of the fuel cell stack or GT generator. In this paper, mass

flows through the system and hence the power level is set by the turbine power fixed at 1 MW. For the turbine-compressor combination drives a generator the energy output was calculated from Eq. (1).

$$W_G = [(W_t \times \eta_{m,t}) - (-\frac{W_c}{\eta_{m,c}})] \times \eta_{gen} \quad (1)$$

Where  $W_G$  is the power output of generator,  $W_t$  is the power output of turbine,  $W_c$  is the power consumption of the compressor  $\eta_{m,t}$  is the mechanical efficiency of the turbine,  $\eta_{m,c}$  is the mechanical efficiency of compressor and  $\eta_G$  is the efficiency of the generator. The desired inlet temperature of the turbine can be manipulated by the addition of fuel to the combustor or recirculation cathode exhaust air to the fuel cell. Two parameters are specified for the consideration of the added fuel or air recirculation to adjust the turbine inlet temperature, as follows:

$$FBR = \frac{\Phi_{201}}{\Phi_2} \quad (2)$$

$$ARR = \frac{\Phi_{108}}{\Phi_{107}} \quad (3)$$

Where FBR is the fuel bypass ratio,  $\Phi_{201}$  is the mass flow of the fuel that bypassed to the combustor,  $\Phi_2$  is the mass flow of the fuel output from the fuel recuperator, ARR is the air recirculation ratio,  $\Phi_{108}$  is the cathode outlet mass flow rate and  $\Phi_{107}$  is mass flow rate of the cathode exhaust recirculation.

In the calculation of system efficiencies four steps can be distinguished:

- Determination of the total energy input
- Determination of the total energy production
- Determination of the total own energy consumption
- Calculation of system efficiencies

The heating value is defined as the energy that must be discharged when heating 1 kilogramme of fuel, when the fuel, oxidant and flue gas are all supplied or discharged at a pressure of 1 atm and a temperature of 25 °C. In gaseous fuels, it is assumed for the higher heating value (HHV) that the water generated by the heating reactions (i.e. not the water that is already present in the gas or in the air) fully condenses. At the lower heating value (LHV), this water is fully present as vapour in the flue gas. The energy efficiencies are calculated based on the LHV of the fuel. Total energy input to the system is:

$$En_{\text{fuel}} = LHV_{\text{syngas fuel}} \times \Phi_{\text{syngas fuel}} \quad (4)$$

$\Phi_{\text{syngas fuel}}$  is the mass flow of the syngas fuel fed to the system (kgs<sup>-1</sup>) and  $LHV_{\text{syngas fuel}}$  is the low heating value of the syngas (kJkg<sup>-1</sup>). For the energy

consumption the electricity driven compressors (not turbine driven compressors) are considered:

$$APC = -\frac{W_c}{\eta_{drive}} \quad (5)$$

APC is the auxiliary power consumption and  $W_c$  is the power absorbed by medium for a compressors which is not turbine driven. The efficiency of the compressor drive  $\eta_{drive}$  is built up by two efficiencies: the mechanical efficiency  $\eta_m$  and the electric efficiency  $\eta_e$ . The total efficiency is then determined as follows:

$$\eta_{drive} = \eta_e \times \eta_m \quad (6)$$

The energy efficiencies are calculated based on the LHV of the fuel. The Gross thermal efficiency, described by Eq. (7), is the ratio of the total produced electricity divided by the mass of the fuel input to the system times the lower heating value. Net thermal efficiency, described by Eq. (8), is defined as the value of the net produced electricity divided by the total fuel heating value.  $P_a$  is the total power consumption of auxiliary components including fuel compressors and air and fuel blowers (kW).

$$\eta_{en,gross} = -\frac{P_{el}}{En_{fuel}} \quad (7)$$

$$\eta_{en,net} = -\frac{P_{el} - P_a}{En_{fuel}} \quad (8)$$

Besides system calculations, Cycle-Tempo can perform exergy calculations, the results of which form the basis for an exergy analysis of the system under consideration. For such an exergy analysis, it is important to have available exergy values of process flows and exergy losses in apparatuses, as well as exergy efficiencies of apparatuses. The gross and net electrical exergetic efficiency are calculated using the following equation:

$$\eta_{ex,gross} = -\frac{P_{el}}{Ex_{fuel}} \quad (9)$$

$$\eta_{ex,net} = -\frac{P_{el} - P_a}{Ex_{fuel}} \quad (10)$$

Table 2 summarizes the assumptions for the developed model of hybrid plant. The anode recycle stream is about 60 wt% of the anode-off gas stream. The operating temperature of the SOFC stacks and outlet temperatures were assumed to be 1000 °C. The cell resistance was assumed to be  $5 \times 10^{-5}$  ohm<sup>2</sup>, and fuel utilization factor of SOFC was assumed to be 80%. Since this study intends to perform a design analysis, the current density of the unit cell is assumed to be constant for all cases. Therefore, different powers

obtained from the analysis can be realized by different cell stack size (e.g., cell active area). In design calculations, cell voltage, current density and fuel utilization factor are specified as an input parameter. On the basis of this data, the program calculates the corresponding cell resistance and cell active area. The mean current density was assumed to be 2500 Am<sup>-2</sup>, and fuel utilization factor of SOFC was assumed to be 85%. The efficiency of the DC/AC converter was assumed to be 97%. The pressure drops at the all devices were assumed to be 0.02 bar.

**Table 2**  
Assumptions for the SOFC–GT model at design point

Component	Unit	Value
Current density	A m <sup>-2</sup>	2500
Equivalent fuel cell resistance	Ω m <sup>2</sup>	5e-5
Fuel utilization factor	%	85
Cathode inlet temperature	°C	900
Anode inlet temperature	°C	900
Operating temperature in the SOFC, T <sub>cell</sub>	°C	950
Operating pressure in the SOFC, P <sub>cell</sub>	bar	3
DIR–SOFC exhaust gas temperature	°C	1000
DIR–SOFC ΔP air/fuel side	bar	0.02
Anode recirculation ratio	%	60
Combustor ΔP	bar	0.02
Fuel and air recuperator hot inlet-cold outlet temperature difference	°C	50
Recuperator ΔP air/gas side	bar	0.02
Turbine inlet temperature	°C	850
Turbine isentropic efficiency	%	85
Compressor isentropic efficiency	%	80
Turbine mechanical efficiency	%	97
Compressor mechanical efficiency	%	97
Isentropic efficiency for fuel compressor and blowers	%	75
Mechanical efficiency for fuel compressor and blowers	%	95
DC/AC conversion efficiency	%	97
Generator efficiency	%	94

## 4. Results

### 4.1 Conventional SOFC–GT hybrid system

The main calculated parameters and the performance of the conventional SOFC–GT hybrid system with regard to energy and exergy conversion are listed in Tables 3 and 4. For the considered system fuel with the flow rate of 0.954 kg/s enters the cycle at 25 °C and 1.013 bar. The corresponding energy input to the system, 4357 kW, is based on the lower heating value of the fuel. However, the corresponding exergy input to the system is 4258 kW.

The fuel input to the system is pressurized at the fuel compressor to 3.05 bar. The power required for this compression is about 150 kW. Then, the fuel is heated in fuel recuperator by the gas turbine discharge stream. The recovered heat in the fuel recuperator is 711 kW. This heat is used to increase the temperature of fuel from 66 °C after the compressor to 586 °C. After fuel recuperator, some portion of the fuel (About 0.309 of the stream 2 in Fig. 1) is bypassed to the combustor

to meet the required fuel cell and turbine inlet temperature.

Furthermore, the fuel stream temperature needs to be increased to the inlet temperature of the SOFC. Therefore, it is further reheated to 713 °C in fuel preheater by the exhaust of the combustor. The transmitted heat of fuel preheater is 125 kW. After that, the preheated fuel mixed with the recycled fuel from the anode exit before entering the SOFC anode inlet. The mass flow rate of the SOFC anode inlet stream is 1.921 kg/s, and its temperature is 900 °C. The mass flow rate of the anode exhaust recirculation is 1.261 kg/s, and its temperature is equal to the outlet temperature of the SOFC, 1000 °C. The inlet air enters the system with the mass flow rate of 8.077 kg/s. The air pressure is increased to 3.05 bar at the air compressor by consuming 1158 kW power. Then, the air is heated in recuperator by the GT discharge stream. The recovered heat in the recuperator is 3667 kW. This heat is used to increase the temperature of air from 162 °C after the compressor to 586 °C. Furthermore, the air stream temperature needs to be increased to the operating temperature of the SOFC. Therefore, it is further reheated to 900 °C in air preheater by the exhaust of the combustor. The transmitted heat of air preheater is 2913 kW. The air stream is then fed to the SOFC cathode inlet.

**Table 3**

Key parameters data for the conventional SOFC–GT hybrid system

Component	Unit	Value
Fuel flow-rate to the system	kg/s	0.954
Air flow-rate to the system	kg/s	8.077
Recovered heat at the fuel recuperator	kW	711
Recovered heat at the air recuperator	kW	3667
Bypassed fuel fraction to the combustor	–	0.309
Fuel flow-rate to the combustor	Kg/s	1.136
Combustor outlet temperature	°C	1124
Combustor outlet mass flow rate	Kg/s	9.032
Exchanged heat at the fuel preheater	kW	125
Exchanged heat at the air preheater	kW	2913
Anode inlet flow ratio	kg/s	1.921
Anode recirculation flow ratio	kg/s	1.261
Anode outlet flow ratio	kg/s	2.102
Cathode inlet flow ratio	kg/s	8.077
Cathode outlet flow ratio	kg/s	7.896
Stack exhaust gas temperature	°C	199

In the SOFC unit, electrochemical reaction takes place, and as a consequence, 1530 kW AC power is generated. The AC efficiency of power generation in the SOFC unit is 50.83 %. In the cathode side of the SOFC, because of the electrochemical reaction in the fuel cell the mass flow rate of air reduces from 8.077 to 7.896 kg/s. While in the anode side, because of the electrochemical reaction and formation of H<sub>2</sub>O, the mass flow rate of the anode increases from 1.921 kg/s to 2.102 kg/s.

**Table 4**

Conventional SOFC–GT hybrid system energy and exergy performance

Parameters	Unit	Value
Energy in fuel input to the system	kW	4357
Exergy in fuel input to the system	kW	4258
SOFC DC power output	kW	1578
SOFC AC power output	kW	1530
SOFC AC efficiency	%	50.83
Gas turbine generator power output	kW	1000
Gas turbine generator efficiency	%	35.98
Auxiliary power consumption	kW	155
Net power output	kW	2376
Net energy efficiency	%	54.53
Net exergy efficiency	%	55.8

The anode off-gas still contains some combustible components, which are combusted in a combustor using the depleted air coming from the fuel cell. The mass flow rate of the combustor outlet is 9.032 kg/s, and its temperature is 1124 °C. The combustor exhaust is used to increase the fuel and air temperature respectively at fuel and air preheaters, before being fed to the GT. The flue gases stream temperature fall to 1113 °C and 850 °C at fuel and air preheater hot outlets streams, respectively. The hot flue gasses leaving the air preheater with a temperature of 850 °C are expanded in the turbine of the GT, which is connected through a shaft with the compressor and a generator. The output power generated in the turbine is 2221 kW, and delivered power in the generator after adjusting for air compressor power consumption is 1000 kW. The efficiency of power generation in the GT unit is 35.98 %. The flow exits the GT at a temperature of 636 °C and pressure of 1.033 bar. This stream preheats the air and fuel stream separately at fuel and air recuperators, and its temperature reduces to 116 °C and 213 °C at streams 112 and 113, respectively. Finally the exhaust gas is discharged to the atmosphere at a temperature of 199 °C. In this system, delivered gross power is 2530 kW and delivered net power after adjusting for auxiliary power consumption is 2376 kW. The net hybrid system efficiency achieved is 54.53%.

#### 4.2 SOFC–GT system with cathode gas recirculation

The main calculated parameters and the performance of the SOFC–GT hybrid system with cathode gas recirculation with regard to energy and exergy conversion are listed in Tables 5 and 6. Syngas with the flow rate of 1.207 kg/s, enters the cycle at 25 °C and 1.013 bar. The corresponding energy and exergy input to the system is, 5510 kW and 5384 kW, respectively, are based on the lower heating value of the fuel. The fuel input to the system is pressurized at the fuel compressor to 3.05 bar and 66 °C at stream 2. The fuel compressor consumes 190 kW. The temperature of stream 2 increases to 588 °C by 902 kW heat transfer at fuel recuperator.

Furthermore, the fuel stream temperature needs to be increased to the inlet temperature of the SOFC. Therefore, it is further reheated to 713 °C in fuel preheater by the exhaust of the combustor. The transmitted heat of fuel preheater is 225 kW. The streams 3 and 4 are then mixed to form stream 5 with a high concentration of steam required by the reforming and water–gas shift reactions (see Fig. 3). The mass flow rate of the SOFC anode inlet stream is 3.515 kg/s, and its temperature is 900 °C. The mass flow rate of the anode exhaust recirculation is 2.308 kg/s, and its temperature is equal to the outlet temperature of the SOFC, 1000 °C. In the anode recycle a fuel blower is used to overcome the pressure drop in the fuel cell. The fuel blower in the anode recycle consumes 8 kW of power.

**Tabel 5**

Key parameters data for the SOFC–GT hybrid system with cathode gas recirculation

Component	Unit	Value
Fuel flow-rate to the system	kg/s	1.207
Air flow-rate to the system	kg/s	7.444
Recovered heat at the fuel recuperator	kW	902
Recovered heat at the air recuperator	kW	3395
Cathode exhaust gas recirculation ratio	–	0.51
Fuel flow-rate to the combustor	Kg/s	1.539
Combustor outlet temperature	°C	1036
Combustor outlet mass flow rate	Kg/s	8.651
Exchanged heat at the fuel preheater	kW	225
Exchanged heat at the air preheater	kW	1767
Anode inlet flow ratio	kg/s	3.515
Anode recirculation flow ratio	kg/s	2.308
Anode outlet flow ratio	kg/s	3.847
Cathode inlet flow ratio	kg/s	14.838
Cathode recirculation flow ratio	kg/s	7.394
Cathode outlet flow ratio	kg/s	14.506
Stack exhaust gas temperature	°C	194

**Tabel 6**

Energy and exergy performance of the SOFC–GT hybrid system with cathode gas recirculation

Component	Unit	Value
Energy in fuel input to the system	kW	5510
Exergy in fuel input to the system	kW	5384
SOFC DC power output	kW	2878
SOFC AC power output	kW	2792
SOFC AC efficiency	%	50.67
Gas turbine generator power output	kW	1000
Gas turbine generator efficiency	%	37.99
Auxiliary power consumption	kW	223
Net power output	kW	3569
Net energy efficiency	%	64.76
Net exergy efficiency	%	66.28

On the other hand, the inlet air enters the system at 25 °C and 1.013 bar with the mass flow rate of 7.444 kg/h. The air pressure is increased to 3.05 bar at the air compressor by consuming 1067 kW of power. The air stream temperature is further increased in air recuperator and air preheater by the GT discharge stream and the combustor exhaust stream,

respectively, and its temperature rises to 588 °C and 796 °C at streams 103 and 104, respectively. The heat duties of air recuperator and air preheater are 3395 and 1767 kW, respectively. The hot compressed air is then mixed with depleted air from the cathode air recycle. This cathode air recycle stream is about 51 wt% of the stream leaving the cathode of the fuel cell. The air stream is then fed to the SOFC at the cathode inlet.

The electrochemical reactions in the SOFC generate 2792 kW AC power. The AC efficiency of power generation in the SOFC is 50.67% (based on LHV). Because of the electrochemical reaction in the anodeside of SOFC and formation of water, the mass flow rate of the anode increases to 3.847 kg/s. The SOFC anode exhaust is then divided into two streams: one is recycled to the anode side of fuel cell and the other is fed to the combustor. In the meantime, due to oxygen companies in the air flow in the SOFC reactions, the molar flow rate of the air reduces from 14.838 to 14.506 kg/s. The SOFC cathode exhaust is then divided into two streams: one is recycled to the cathode side of SOFC and the other is fed to the combustor, where it mixes with the anode exhaust stream. This mixture is combusted in the combustor, so the temperature of combustion products increases to 1036 °C. The mass flow rate of the combustor exhaust is 8.651 kg/s. The combustor exhaust is used to increase fuel and air temperature to 713 °C and 796 °C at fuel and air preheater, respectively before being fed to the GT. The TIT is fixed at the 850 °C by adjusting the cathode exhaust recirculation ratio. The hot flue gasses leaving the air preheater with a temperature of 850 °C are expanded in the turbine of the GT unit, which is connected through a shaft with the compressor and a generator. The output power generated in the turbine is 2131 kW, and delivered power in the generator after adjusting for air compressor power consumption is 1000 kW. The efficiency of power generation in the GT unit is 37.99%. The combustion products leave the GT at a temperature of 638 °C and pressure of 1.033 bar. This stream heats the fuel at fuel recuperator and the air at air recuperator. Eventually the exhaust is discharged to the atmosphere at a temperature of 194 °C. Energy and exergy available at the stack are considered to be the losses to the environment. In this system, delivered gross power is 3792 kW and delivered net power after adjusting for auxiliary power consumption is 3569 kW. The net hybrid system efficiency achieved is 64.76%.

#### 4.3 Comparison of the both systems

As Fig. 5 show, due to cathode recirculation the air mass flow rate to the system in the configuration with cathode recirculation is slightly lower than that in the conventional configuration (7.44 kg/s vs. 8.077 kg/s, respectively). While, comparison of the SOFC cathode inlet air mass flow in Fig. 5 shows that the cathode inlet air mass flow of the SOFC in the configuration

with cathode recirculation is significantly higher than that in the configuration without cathode recirculation (14.838 kW vs. 8.077 kg/s, respectively). The reason is when the fuel recuperator exhaust is partially bypassed to the combustor, in order to adjust the turbine, anode and cathode inlet temperature, before entering the SOFC, the mass flow rate of the anode inlet reduces from 3.515 kg/s in the cycle with cathode recirculation to 1.921 kg/s in the cycle without cathode recirculation. This means lower cooling air required to keep the fuel cell at the required operating temperature in the conventional configuration.

The comparison of energy input to the system for two configurations (see Fig. 6) shows that the energy input to the system is higher in the configuration with cathode recirculation (5510 kW vs. 4357 kW, respectively). The reason is when the SOFC cathode exhaust is partially recycled before entering the combustor, the air mass flow rate of the combustor reduces from 7.896 kg/s in the cycle without cathode recirculation to 7.112 kg/s in the cycle with cathode recirculation. As low air is entered to the combustor, and there is no variation in the turbine inlet temperature and pressure ratio and since the generator produces is fixed, the mass flow through the turbine decreases. This causes higher fuel input to the system and hence the energy input to the system increases, as shown in Fig. 6. The exergy input of both systems has a similar changing trend as energy input (5384 kW vs. 4258 kW, respectively).

As Fig. 7 show, due to higher air mass flow rate to the system and hence higher mass flow through the turbine and since the generator produces is fixed, air compressor power consumption and hence gas turbine power production in the conventional configuration is slightly higher than that in the configuration with cathode recirculation (1158 and 2221 kW vs. 1067 and 2131 kW, respectively).

On the other hand, due to higher fuel mass flow rate to the system and hence higher mass flow through the fuel compressor, fuel compressor power consumption in the configuration with cathode gas recirculation is higher than that in the conventional configuration, as shown in Fig. 8. (190 kW vs. 150 kW, respectively).




Fig. 5 Comparison of the air flow to the system and cathode inlet air flow for two configurations




Fig. 6 Comparison of the energy and exergy input to the system for two configurations




Fig. 7 Comparison power of main components of the gas turbine unit for two configurations




Fig. 8 Comparison power consumption of the auxiliary units for two configurations

In the cycle without cathode recirculation, the cathode recirculation flow rate is zero and that is why in Fig. 8 air blower power consumption is removed. In addition, due to higher power consumption of the fuel compressor and air blower consumption, the total auxiliary power consumption of the hybrid system in the configuration with cathode recirculation is 223 kW, which is higher than in the total auxiliary power consumption of the configuration without cathode recirculation at 155 kW.

Comparison of the SOFC AC output power in Fig. 9 shows that the output power of the SOFC in the configuration without cathode recirculation is

significantly lower than that in the configuration with cathode recirculation (1530 kW vs. 2792 kW, respectively). The reason is when the fuel recuperator exhaust is partially bypassed to the combustor (about 31 wt% of the stream leaving the cold side of the fuel recuperator) before entering the fuel preheater, the fuel mass flow rate of the SOFC anode inlet reduces from 3.515 kg/s in the cycle without cathode recirculation to 1.921 kg/s in the cycle with cathode recirculation. Therefore, there is less power generated in the SOFC of the conventional configuration.

On the other hand, due to higher SOFC power output of the configuration with cathode recirculation and since the generator power produce of both cycle without and with cathode recirculation is equal to 1000 kW, gross output power of the SOFC–GT hybrid system in the configuration with cathode recirculation is significantly higher than that in the configuration without cathode recirculation (3792 kW vs. 2530 kW, respectively) as shown in Fig. 9. This is also the reason for the higher net output power of the SOFC–GT hybrid system in the cycle with cathode recirculation in comparison to the cycle without cathode recirculation (3569 kW vs. 2376 kW, respectively), despite the higher total auxiliary power consumption (see Figs. 8 ). In addition, due to higher gross and net output power, the gross and net energy efficiency of the hybrid system in the configuration with cathode gas recirculation are 68.82 and 64.76 %, respectively, which is significantly higher than that in the configuration without cathode gas recirculation at 58.07 and 54.53 %, respectively (see Figs. 10 ). The gross and net exergy efficiency of both systems has a similar changing trend as energy input (70.43 and 66.28% vs. 59.43 and 55.8 %, respectively).

Fig. 11 and 12 illustrates the exergy loss and destruction balance for two configurations. Apparatuses included in each unit are given in Table 7. It is observed that, in both systems, there is a large amount of exergy loss to the environment; about 25 % or 467 kW of the total exergy input in the conventional configuration and about 26 % or 484 kW of the total exergy input in the configuration with cathode recirculation. This high quality energy can be used further for useful energy production such as a bottoming cycle, space heating or cooling etc. The exergy available at the exhaust gas is considered as a loss here. As Figs. 11 and 12 shows, due to higher fuel mass flow rate through the fuel cell and hence higher electrochemical reactions, the exergy destruction in the fuel cell (FC) in the configuration with cathode recirculation is significantly higher than that in the fuel cell in the conventional configuration (13 % or 231 kW vs. 7 % or 127 kW, respectively). However, the exergy destruction of the combustion chamber (CC) in the configuration without cathode recirculation, due to the bypassed additional fuel into the CC, is significantly higher than that in the configuration with cathode recirculation (18 % or 347 kW vs. 11 % or 194 kW, respectively).




Fig. 9 Comparison power of main components of the hybrid system for two configurations




Fig. 10 Comparison performance of the hybrid system for two configurations

Table 7 Apparatuses included in each unit

Unit	CS (see Figs. 1 and 4)	CRS (see Figs. 3 and 4)
Fuel heating system (FHS)	2, 6 & 7	2, 3 & 4
Air heating system (AHS)	103 & 104	103, 104 & 105
Fuel cell (FC)	8	5
Combustion chamber (CC)	105	108
Gas turbine (GT)	106	106
Air compressor (AC)	102	102
Stack	109	109
Other	108, 4 & Generator	108 & Generator




Fig. 11 Exergy destruction of the conventional configuration in percentage of total exergy destroyed




Fig. 12 Exergy destruction of the configuration without cathode recirculation in percentage of total exergy destroyed

## 5. Conclusion

In this paper the SOFC-GT hybrid system fuelled by syngas from biomass gasification was evaluated by thermodynamic calculations. Two alternative options were proposed to provided, required heat for the heated fuel and air streams to the anode and cathode inlet temperature.

Although the generator power produce of both cycle with and without cathode recirculation were equal to 1000 kW, the SOFC power output of the cycle with cathode recirculation was much higher than that in the cycle without cathode recirculation, which means higher efficiency for the same generator power produce. Also, the gross and net output power of the system in the cycle with cathode recirculation was higher, whereas, the total auxiliary power consumption of the hybrid system was higher in the cycle with cathode recirculation.

The comparison of the system performance indicated that gross energy and exergy efficiency of the SOFC-GT hybrid system with cathode gas recirculation was 68.82 and 70.43 %, respectively, which was much higher than that in the cycle without cathode recirculation at 58.07 and 59.43 %, respectively, whereas, the energy and exergy input to the system was higher in the cycle with cathode exhaust gas recirculation. Also, despite the high total auxiliary power consumption, the net energy and exergy efficiency in the cycle with cathode

recirculation was higher (64.76 and 66.28 % vs. 54.53 and 55.8 %, respectively).

## References

- Ankur scientific energy technologies pvt. ltd, <http://www.ankurscientific.com/range.htm>; 2010.
- Aravind, P.V., Woudstra, T., Woudstra, N. & Spliethoff, H. (2009) Thermodynamic evaluation of small scale systems with biomass gasifiers, solid oxide fuel cells with Ni/GDC anodes and gas turbines. *J Power Sources*, 190(2), 461–75.
- Delft University of Technology. (2017) Cycle-tempo software (Release 5.0), <http://www.asimptote.nl/software/cycle-tempo>.
- Delft University of Technology. (2017) Cycle-tempo manuals <http://www.asimptote.nl/assets/media/7d155f62-ffe2-4a9e-9f33-bb003c80bd2b.pdf>
- Hirschenhofer, J.H., Stauler, D.B., Engleman, R.R. & Klett, M.G. (1998) Fuel cell handbook. 4th ed. Parsons Corporation Reading P.A. for U.S. Department of Energy.
- Kuchonthara, P., Bhattacharya, S. & Tsutsumi, A. (2003) Combinations of solid oxide fuel cell and several enhanced gas turbine cycles. *Journal of Power Sources*, 124, 65–75.
- McLarty, D., Kuniba, Y., Brouwer, J., Samuelsen, S. (2012) Experimental and theoretical evidence for control requirements in solid oxide fuel cell gas turbine hybrid systems. *J Power Sources*, 209, 195–203.
- Park, S.K. & Kim, T.S. (2006) Comparison between pressurized design and ambient pressure design of hybrid solid oxide fuel cell gas-turbine systems. *J Power Sources*, 158, 225–44
- Park, S.K., Kim, T.S., Sohn, J.L. & Mech, J. (2009) Influence of steam injection through exhaust heat recovery on the design performance of solid oxide fuel cell — gas turbine hybrid systems. *J Mech Sci Technol*, 23,550–8.
- Saebea, D., Patcharavochot, Y. & Arpornwichanop, A. (2012) Analysis of an ethanolfuelled solid oxide fuel cell system using partial anode exhaust gas recirculation. *J Power Sources*, 208, 120–30.
- Rokni, M. (2010) Plant characteristics of an integrated solid oxide fuel cell cycle and a steam cycle. *Energy* 2010;35:4691–9.
- Rokni, M. (2010) Thermodynamic analysis of an integrated solid oxide fuel cell cycle with a rankine cycle. *Energy Conversion and Management*, 51,2724–32
- Toonssen, R., Aravind, P.V., Smit, G., Woudstra, N. & Verkooyen, A.H.M. (2010) System study on hydrothermal gasification combined with a hybrid solid oxide fuel cell gas turbine. *Fuel Cells*, doi:10.1002/fuce.2009001

Website:

<https://www.siemens.com/global/en/home.html>